



Product Service

CERTIFICATE

No. Z2 120912 0001 Rev. 00

Holder of Certificate: **Sengi Solar Importacao E Exportacao Industria E Comercio Ltda**
AV Aracy Tanaka Biazetto 6508 Brcao03 Regiao Do Lago
85.816-455 Cascavel PR
BRAZIL

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
(Mono Crystalline Silicon Photovoltaic (PV) Module)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290233008001

Valid until: 2028-06-27

Date, 2023-06-28

(Billy Qiu)

CERTIFICATE

No. Z2 120912 0001 Rev. 00

Model(s):

1500V series:

SV1S72-xxxW (xxx=535-555, in steps of 5);

xxx stands for rated output power at STC.

Parameters:

Safety class:	Class II
Max. system voltage:	1500 V d.c.
Fire safety class:	Class C according to UL790
Construction:	Framed, with Junction box, Cable and Connectors

Tested according to:

IEC 61215-1:2021
EN 61215-1:2021
IEC 61215-1-1:2021
EN 61215-1-1:2021
IEC 61215-2:2021
EN 61215-2:2021
IEC 61730-1:2016
EN IEC 61730-1:2018
IEC 61730-2:2016
EN IEC 61730-2:2018