



# Certificate of compliance

**Applicant:** SolarEdge Technologies Ltd.  
1 HaMada Street  
Herzliya 4673335  
Israel

**Product:** Photovoltaic (PV) inverter

<b>Model:</b>	SE50K	SE55K	SE66.6K	SE75K
	SE82.8K	SE90K	SE90K	SE100K
	SE66.6K*	SE80K*	SE100K*	SE120K*

**Note:** \* 480 V mains voltage models

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2008/2014 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

## Applied rules and standards:

### IEC 61727:2004

Photovoltaic (PV) systems – Characteristics of the utility interface

### IEC 62116:2008 / IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** 20TH0532-IEC61727\_0

**Certificate number:** U21-0498

**Certification program:** NSOP-0032-DEU-ZE-V01

**Date of issue:** 2021-06-04

**Certification body**



Thomas Lammel



Certification body Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065  
A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH